


NOTES:

1. FUEL SUPPLY: 3/8" FUEL RETURN: 3/8"
2. DUCT FLANGE WIDTH: 25.63"
3. UNIT OFFSET 3.00" TOWARDS LSFG
4. APPROX. BREAKER LOCATION SHOWN
5. (XX.XX) DIMENSIONS ARE FOR REFERENCE ONLY

LEVEL:	DESCRIPTION:	DATE:	BY:
REVISIONS:			
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.			
 <b>BLUE STAR</b> Power Systems Inc.		2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003   1 507 345 1776	
DRAWN BY: RPS	ENGINE: 4045HFG04	BASE: 23660	TANK: NONE
DATE: 11-18-2022	GENERATOR: UCI224F	HSG: NONE	SIZE: B
		SCALE: NONE	SHEET: 1 OF 1