



- NOTES:
 1. FUEL SUPPLY: 5/8" FUEL RETURN: 1/2"
 2. DUCT FLANGE WIDTH 75.75"
 3. APPROX. BREAKER LOCATION SHOWN
 4. LOUVERS NOT SHOWN IN REAR VIEW
 5. (OPTIONAL): EXHAUST HOOD INCLUDED LEVEL 3 ONLY
 6. (OPTIONAL): EXHAUST ROUTED THROUGH EXHAUST HOOD LEVEL 3 ENCLOSURE ONLY
 7. (OPTIONAL): SOUND ATTENUATION FOAM INCLUDED LEVEL 2 & 3 ENCLOSURES ONLY
 8. (XX.XX) DIMENSIONS ARE FOR REFERENCE ONLY

LEVEL:	DESCRIPTION:	DATE:	BY:
REVISIONS:			
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.			
		2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 1 507 345 1776	
DRAWN BY: RPS	ENGINE: S12H-Y2PTAW-1	BASE: 18689	TANK: NONE
DATE: 12-05-2022	GENERATOR: S6L1D-E	HSG: WPE-115	SIZE: B
		SCALE: NONE	SHEET: 1 OF 1