




48HR / 1,080GL FUEL TANK
 JD250-02, JD275-02, JD300-02
 PD250-01, PD300-01
 VD230-01, VD250-01, VD250-03,
 VD275-01, VD300-01
 VD250-02FT4, VD300-02FT4
 LV0 / LV1 / LV2 / LV3



- NOTES:
1. MATERIAL: PER UL/ULC REQUIREMENTS
 2. SECONDARY CONTAINMENT TANK
 3. TANK TO INCLUDE:
 - FUEL SUPPLY/RETURN DIP TUBES
 - LIFTING/TIE-DOWN BRACKETS

MATERIAL: **SEE NOTES** FINISH: **BLACK HAMMERED**

R06	CHANGED E-VENTS TO 5.00 & ADDED STEP HOLES	02-11-22	CRC
LEVEL:	DESCRIPTION:	DATE:	BY:
REVISIONS:			
<small>THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.</small>			
2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 1 507 345 1776			
TANK SB 1080GL DW SC UL/ULC W/ STUB-UP			
	NAME	DATE	SIZE PART NUMBER:
	DRAWN BY: CRC	12-07-22	B 18010
DO NOT SCALE DRAWING	APPROVED: CRC	12-07-22	SCALE: NONE APPROX. WEIGHT: 2,900LBS SHEET 1 OF 1