



- NOTES:
1. FUEL SUPPLY: 3/8" FUEL RETURN: 1/4"
  2. RADIATOR CORE WIDTH 43.31"
  3. APPROX. BREAKER LOCATION SHOWN
  4. (OPTIONAL): EXHAUST HOOD INCLUDED LEVEL 3 ONLY
  5. (OPTIONAL): EXHAUST ROUTED THROUGH EXHAUST HOOD LEVEL 3 ENCLOSURE ONLY
  6. (OPTIONAL): SOUND ATTENUATION FOAM INCLUDED LEVEL 2 & 3 ENCLOSURES ONLY
  7. (XX.XX) DIMENSIONS ARE FOR REFERENCE ONLY

LEVEL:	DESCRIPTION:	DATE:	BY:
REVISIONS:			
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.			
 <b>BLUE STAR</b> Power Systems Inc.		2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003   1 507 345 1776	
DRAWN BY: RPS	ENGINE: TWD1673GE	BASE: 23633	TANK: NONE
DATE: 12-05-2022	GENERATOR: HCI534E	HSG: WPE-116	SIZE: B
		SCALE: NONE SHEET: 1 OF 1	