


- NOTES:
1. FUEL CONNECTION 3.00" NPT
 2. RADIATOR CORE WIDTH 12.38"
 3. APPROX. BREAKER LOCATION SHOWN
 4. LOUVERS NOT SHOWN IN REAR VIEW
 5. (OPTIONAL): EXHAUST HOOD INCLUDED LEVEL 3 ONLY
 6. (OPTIONAL): EXHAUST ROUTED THROUGH EXHAUST HOOD LEVEL 3 ENCLOSURE ONLY
 7. (OPTIONAL): SOUND ATTENUATION FOAM INCLUDED LEVEL 2 & 3 ENCLOSURES ONLY
 8. (XX.XX) DIMENSIONS ARE FOR REFERENCE ONLY

| LEVEL: | DESCRIPTION: | DATE: | BY: |
|--------|--------------|-------|-----|
| | | | |

REVISIONS:

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.



DRAWN BY:
RPS
DATE:
12-12-2022
ENGINE:
NG 40L
GENERATOR:
S6L1D-C

BLUE STAR
Power Systems Inc.

2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 | 1 507 345 1776

| | |
|---------------------------|---------------|
| BASE: 18670 | TANK: NONE |
| HSG: WPE-115 | SIZE: B |
| SCALE: NONE SHEET: 1 OF 1 | |