




DRAWING:

19997

72HR / 1,125GL FUEL TANK

JD150-01, JD200-01
 PD150-01, PD180-01, PD200-01
 LVO / LV1 / LV2 / LV3



- NOTES:
1. MATERIAL: PER UL/ULC REQUIREMENTS
 2. SECONDARY CONTAINMENT TANK
 3. TANK TO INCLUDE:
 - FUEL SUPPLY/RETURN DIP TUBES
 - LIFTING/TIE DOWN BRACKETS

MATERIAL: SEE NOTES

FINISH: BLACK HAMMERED



REMOVE ALL BURRS AND SHARP EDGES

TOLERANCE UNLESS OTHER SPECIFIED:

FRACTIONAL: ± 1/32
 ANGULAR: ± 1°
 X.X = ± .1
 X.XX = ± .03
 X.XXX = ± .010

DIMENSIONS ARE IN INCHES

DO NOT SCALE DRAWING

R08	MOVE VENTS & ADD 1.50 & 2.00 NPT EXTRA FITTINGS	12-05-23	CRC
LEVEL:	DESCRIPTION:	DATE:	BY:

REVISIONS:

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.

BLUE STAR
Power Systems Inc.
 2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 | 1 507 345 1776

TANK SB 1125GL DW SC UL/ULC W/ STUB-UP

NAME	DATE	SIZE	PART NUMBER:
DRAWN BY: CRC	12-07-22	B	19997
APPROVED: CRC	12-07-22	SCALE: NONE	APPROX. WEIGHT: 3,050Lbs SHEET 1 OF 1