




72HR / 1,620GL FUEL TANK
 JD250-02, JD275-02, JD300-02
 PD250-01, PD300-01
 VD230-01, VD250-01, VD250-03,
 VD275-01, VD300-01
 VD250-02FT4, VD300-02FT4
 LV0 / LV1 / LV2 / LV3



- NOTES:
 1. MATERIAL: PER VENDOR'S UL/ULC REQUIREMENTS
 2. SECONDARY CONTAINMENT TANK
 3. TANK TO INCLUDE:
 -FUEL SUPPLY/RETURN DIP TUBES
 -LIFTING/TIE-DOWN BRACKETS

MATERIAL: SEE NOTES FINISH: BLACK HAMMERED

REMOVE ALL BURRS AND SHARP EDGES
 TOLERANCE UNLESS OTHER SPECIFIED:
 FRACTIONAL: ± 1/32
 ANGULAR: ± 1°
 X.X = ± .1
 X.XX = ± .03
 X.XXX = ± .010

R04	CHANGED LEFT SUPPLY/RETURN TO 2.00 X .75	04-01-21	CRC
LEVEL:	DESCRIPTION:	DATE:	BY:
REVISIONS:			
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.			
<h1>BLUE STAR</h1> <h2>Power Systems Inc.</h2> <p>2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 1 507 345 1776</p>			
TANK SB 1620GL DW SC UL/ULC W/ STUB-UP			
	NAME	DATE	SIZE PART NUMBER:
	DRAWN BY: CRC	12-07-22	B 20773
	APPROVED: CRC	12-07-22	SCALE: NONE APPROX. WEIGHT: 4,300 LBS SHEET 1 OF 1