



REVISIONS:

| LEVEL: | DESCRIPTION: | DATE: | BY: |
|--------|--------------|-------|-----|
| NA     | NA           | NA    | NA  |

**BLUE STAR**  
Power Systems Inc.

|                    |          |
|--------------------|----------|
| ENG: 1706D-E93TAG1 | GEN: 432 |
|--------------------|----------|

|             |             |         |
|-------------|-------------|---------|
| RAD: W/ ENG | BASE: 23539 | HSG: NA |
|-------------|-------------|---------|

|                |         |                |
|----------------|---------|----------------|
| DATE: 02-15-21 | BY: CLJ | DRAWN TO SCALE |
|----------------|---------|----------------|

NOTES:

1. BREAKER LOCATION IS APPROXIMATE
2. DUCT FLANGE WIDTH: 39.25"
3. FUEL SUPPLY: 5/8" FUEL RETURN: 3/8"
4. (XX.XX) DIMENSIONS ARE FOR REFERENCE ONLY