




48HR / 1,420GL FUEL TANK  
 VD350-01, VD400-01  
 LV0 / LV1 / LV2 / LV3



- NOTES:
- MATERIAL: PER UL/ULC REQUIREMENTS
  - SECONDARY CONTAINMENT TANK
  - TANK TO INCLUDE:
    - FUEL SUPPLY/RETURN DIP TUBES
    - LIFTING/TIE-DOWN BRACKETS

MATERIAL: SEE NOTES FINISH: BLACK HAMMERED

R07	ADDED 1.50 & 2.00 NPT FITTINGS TO FRONT OF TANK	11-06-20	CRC
LEVEL:	DESCRIPTION:	DATE:	BY:

REVISIONS:  
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.

REMOVE ALL BURRS AND SHARP EDGES  
 TOLERANCE UNLESS OTHER SPECIFIED:  
 FRACTIONAL: ± 1/32  
 ANGULAR: ± 1°  
 X.X = ± .1  
 X.XX = ± .03  
 X.XXX = ± .010  
 DIMENSIONS ARE IN INCHES  
 DO NOT SCALE DRAWING



TANK SB 1420GL DW SC UL/ULC W/ STUB-UP

NAME	DATE	SIZE	PART NUMBER:
CRC	12-08-22	B	17999
APPROVED:	CRC	SCALE: NONE	APPROX. WEIGHT: 3,700 LBS
		SHEET 1 OF 1	