




DRAWING: 20559

24HR / 1,000GL FUEL TANK
 VD550-02FT4, VD600-02FT4
 LV0 / LV1 / LV2 / LV3




- NOTES:
1. MATERIAL: PER UL/ULC REQUIREMENTS
 2. SECONDARY CONTAINMENT TANK
 3. TANK TO INCLUDE:
 - FUEL SUPPLY/RETURN DIP TUBES
 - LIFTING/TIE DOWN BRACKETS

MATERIAL: SEE NOTES

FINISH: BLACK HAMMERED

R05	UPDATED INTERNAL COMPONENTS	03-03-20	CRC
LEVEL:	DESCRIPTION:	DATE:	BY:

REVISIONS:
 THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.



REMOVE ALL BURRS AND SHARP EDGES

TOLERANCE UNLESS OTHER SPECIFIED:

FRACTIONAL: ± 1/32
 ANGULAR: ± 1'
 X.X = ± .1
 X.XX = ± .03
 X.XXX = ± .010

BLUE STAR
Power Systems Inc.
 2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 | 1 507 345 1776

TANK SB 1000GL DW SC UL/ULC W/ STUB-UP

DIMENSIONS ARE IN INCHES	DRAWN BY: CRC	DATE: 12-09-22	SIZE: B	PART NUMBER: 20559
DO NOT SCALE DRAWING	APPROVED: CRC	DATE: 12-09-22	SCALE: NONE	APPROX. WEIGHT: 3,650 LBS