




48HR / 2,000GL FUEL TANK
 VD550-02FT4, VD600-02FT4
 LV0 / LV1 / LV2 / LV3



- NOTES:
1. MATERIAL: PER UL/ULC REQUIREMENTS
 2. SECONDARY CONTAINMENT TANK
 3. TANK TO INCLUDE:
 - FUEL SUPPLY/RETURN DIP TUBES
 - LIFTING/TIE DOWN BRACKETS

MATERIAL: SEE NOTES FINISH: BLACK HAMMERED

LEVEL:		DESCRIPTION:		DATE:	BY:
REVISIONS:					
<small>THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.</small>					
<h1 style="margin: 0;">BLUE STAR</h1> <h2 style="margin: 0;">Power Systems Inc.</h2> <small>2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 1 507 345 1776</small>					
<h3 style="margin: 0;">TANK SB 2000GL DW SC UL/ULC W/ STUB-UP</h3>					
DIMENSIONS ARE IN INCHES		DRAWN BY: CRC	DATE: 12-09-22	SIZE: B	PART NUMBER: 21855
DO NOT SCALE DRAWING		APPROVED: CR	DATE: 12-09-22	SCALE: NONE	APPROX. WEIGHT: 5,600 LBS
SHEET 1 OF 1					