




72HR / 3,000GL FUEL TANK  
 VD550-02FT4, VD600-02FT4  
 LV0 / LV1 / LV2 / LV3



- NOTES:  
 1. MATERIAL: PER UL/ULC REQUIREMENTS  
 2. SECONDARY CONTAINMENT TANK  
 3. TANK TO INCLUDE:  
 -FUEL SUPPLY/RETURN DIP TUBES  
 -LIFTING/TIE DOWN BRACKETS

MATERIAL: SEE NOTES FINISH: BLACK HAMMERED

REMOVE ALL BURRS AND SHARP EDGES  
 TOLERANCE UNLESS OTHER SPECIFIED:  
 FRACTIONAL: ± 1/32  
 ANGULAR: ± 1'  
 X.X = ± .1  
 X.XX = ± .03  
 X.XXX = ± .010

R01	ADDED 1.50 & 2.00 NPT EXTRA FITTINGS	07-05-23	CRC
LEVEL:	DESCRIPTION:	DATE:	BY:
REVISIONS:			
<small>THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.</small>			
<h1>BLUE STAR</h1> <h2>Power Systems Inc.</h2> <small>2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003   1 507 345 1776</small>			
TANK SB 3000GL DW SC UL/ULC W/ STUB-UP			
	NAME	DATE	SIZE PART NUMBER:
	CRC	12-09-22	B 21856
	APPROVED:	CRC	SCALE: NONE APPROX. WEIGHT: 7,800 LBS SHEET 1 OF 1