


- NOTES:
1. FUEL CONNECTION 3.00" NPT
  2. RADIATOR CORE WIDTH 64.50"
  3. APPROX. BREAKER LOCATION SHOWN
  4. (OPTIONAL): EXHAUST HOOD INCLUDED LEVEL 3 ONLY
  5. (OPTIONAL): EXHAUST ROUTED THROUGH EXHAUST HOOD LEVEL 3 ENCLOSURE ONLY
  6. (OPTIONAL): SOUND ATTENUATION FOAM INCLUDED LEVEL 2 & 3 ENCLOSURES ONLY
  7. (XX.XX) DIMENSIONS ARE FOR REFERENCE ONLY

LEVEL:	DESCRIPTION:	DATE:	BY:
--------	--------------	-------	-----

REVISIONS:

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BLUE STAR POWER SYSTEMS, INC. ANY REPRODUCTION, IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION IS PROHIBITED.



DRAWN BY:

RPS

DATE:

12-09-2022

ENGINE:

NG 21.9L

GENERATOR:

S4L1D-F41

**BLUE STAR**  
Power Systems Inc.

2250 CARLSON DRIVE, NORTH MANKATO, MINNESOTA 56003 | 1 507 345 1776

BASE:

31088

HSG:

WPE-106

TANK:

NONE

SIZE:

B

SCALE: NONE SHEET: 1 OF 1